

SIX FLAGS NEW ENGLAND	
SUBJECT: EMERGENCY LIGHTING	SAFETY REFERENCE MANUAL
SECTION: 11	
EFFECTIVE: January 2016	SUPERSEDES: ALL PREVIOUS

11.1 PURPOSE

This Emergency Action Guide will establish procedures to provide additional portable emergency lighting at SIX FLAGS NEW ENGLAND. This procedure will go into effect in the event of a power failure during the evening hours when the Park is in operation.

11.2 POLICY

All departments will work “hand-in-hand” to accomplish effective emergency lighting to those areas not already covered with permanently mounted emergency lighting units. Virtually all permanent structures are equipped with permanent emergency lighting systems. The area of concern will be the smaller stands, i.e. Soda, Pretzel, and Icee stands, where portable lights will be issued. Priority will be given at all times to locations where any incidents have occurred.

11.3 PROCEDURES

In the event of a power failure during the evening hours, when making the deployment of portable emergency lighting, the following procedures will be followed in sequence.

These permanently mounted emergency lighting generators turn on automatically as a unit every Monday for a functional test.

A. Generator Locations and Coverage (**Update Section A, for your park**)

1. *Human Resources Building*
2. *Maintenance Building*
3. *Blizzard River Ride*
4. *Skycoaster*
5. *Splashwater Falls*
6. *Sky Ride Platforms*

SIX FLAGS NEW ENGLAND	
SUBJECT: EMERGENCY LIGHTING	SAFETY REFERENCE MANUAL
SECTION: 11	
EFFECTIVE: January 2016	SUPERSEDES: ALL PREVIOUS

7. *First Aid/Security*

8. *Scream Towers*

B. In addition to the above, the Park has available a 150KW generator on a trailer. This unit can be towed anywhere that may need an additional power source. The location of storage is at the Mechanic Shop.

C. PERMANENTLY MOUNTED EMERGENCY LIGHTS

These units are operated by battery. Simply, if the power is disrupted, the batteries would take over and light the area within that structure automatically. Along with the emergency lights, the exit lights also light up.

Background – Currently situated throughout the complex, there are approximately 306 permanently mounted Emergency Lights and Exit Lights within existing structures. These 306 units control 917 lights to include their remote lights and exit lights.

All lights should be tested on a monthly basis

D. ADDITIONAL PORTABLE LIGHTS AND GENERATORS

The Fire Department, if needed, will supply and set-up emergency generators for lighting or machinery where needed. Generators would be obtained from the Maintenance Department. The following equipment is stored at Maintenance:

1 – Honda Generator
10 – 100' extension cords
250' extension cord

Additional lighting units and extension cords will be available through the Maintenance Division if needed.